



20-21 Wagaraw Road – Bldg. 35E, Fair Lawn, NJ 07410
PH (973) 636-9145 FAX (973) 636-9144
Email: Envirovision@optonline.net

CLIENT: Scotch Plains – Fanwood School District	Project No. 21-226
PROJECT: Lead (Pb) in Water Sampling	School One
ADDRESS: 563 Willow Ave, Scotch Plains, NJ 07076	
FIELD TECHNICIAN(S) Cathy DiNardo	
REPORT DATE: January 11, 2022	

As per your request, EnviroVision Consultants, Inc. was contracted by Scotch Plains – Fanwood School District to conduct Lead (Pb) in water sampling at School Number One on December 18, 2021. The sample locations, in addition to a unique sample location code was determined/assigned by school district personnel. The school district performed the proper flushing of outlets prior to sampling and EnviroVision was instructed to collect only first draw samples for this sampling event. The school district's corresponding flushing logs should be attached to this report.

The facility was closed at the time of sampling in order to prevent occupants from utilizing any water outlets. After flushing, the water in the facility must remain motionless in the plumbing fixtures for a minimum of 8 hours, but no more than 48 hours. Cold water samples were collected in pre-cleaned high-density polyethylene (HDPE) 250mL wide mouth bottles.

Samples were analyzed at EMSL Analytical Inc. in Cinnaminson, New Jersey *(NJDEP# 03036), accredited in accordance with NELAC (National Environmental Laboratory Accreditation Conference). The analytical method utilized was inductively coupled plasma mass spectrometry ICP-MS (EPA 200.8).

All thirty-five initially requested samples were collected from School Number One. An additional blank sample was collected as required.

Results: All of the samples analyzed were either "None Detected" or less than the EPA established threshold for lead in drinking water of 15 parts per billion (ppb). The action level has been further defined for compliance by the New Jersey Department of Environmental Protection Agency as an amount greater than or equal to 15.5 ug/L (1ug/L = 1ppb). When a water outlet/faucet meets or exceeds the USEPA/NJDEP threshold, EnviroVision recommends that the outlet/faucet be immediately put out of service until the system can be further evaluated and proper remedial action is achieved.



Page 2 (School One)

Project Number 21-226

If you have any questions, or if we could be of any further assistance, please feel free to contact our office. EnviroVision looks forward to providing you with the service and attention to detail you have come to expect from us.

Sincerely,
EnviroVision Consultants, Inc.

Cathy DiNardo

Cathy DiNardo, Project Manager

Attached: Lab results, Associated data sheets,



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn: **Fred Larson**
EnviroVision Consultants, Inc
20-21 Wagaraw Rd
Bldg 35E
Fair Lawn, NJ 07410

1/6/2022

Phone: (973) 636-9145
Fax: (973) 636-9144

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 12/20/2021. The results are tabulated on the attached data pages for the following client designated project:

21-226 Scotch Plains/ Fanwood PS-School One ES

The reference number for these samples is EMSL Order #012115041. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012115041
CustomerID: RAMA51
CustomerPO: 21-226
ProjectID:

Attn: **Fred Larson**
EnviroVision Consultants, Inc
20-21 Wagaraw Rd
Bldg 35E
Fair Lawn, NJ 07410

Phone: (973) 636-9145
Fax: (973) 636-9144
Received: 12/20/2021 09:00 AM

Project: 21-226 Scotch Plains/ Fanwood PS-School One ES

Analytical Results

Client Sample Description		SOWCF1-128U Hall By 128	Collected:		12/18/2021 7:00:00 AM	Lab ID:		012115041-0001
Method	Parameter	Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS								
200.8	Lead	ND	1.00 µg/L		1/4/2022	KB	1/5/2022 00:16	KB
Client Sample Description		SOWCF1-128L Hall By 128	Collected:		12/18/2021 7:00:00 AM	Lab ID:		012115041-0002
Method	Parameter	Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS								
200.8	Lead	ND	1.00 µg/L		1/4/2022	KB	1/5/2022 00:20	KB
Client Sample Description		SOWCF1-128BF Hall By 128	Collected:		12/18/2021 7:00:00 AM	Lab ID:		012115041-0003
Method	Parameter	Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS								
200.8	Lead	ND	1.00 µg/L		1/4/2022	KB	1/5/2022 00:22	KB
Client Sample Description		SODWF1-1-101 Classroom 101	Collected:		12/18/2021 7:04:00 AM	Lab ID:		012115041-0004
Method	Parameter	Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS								
200.8	Lead	2.83	1.00 µg/L		1/4/2022	KB	1/5/2022 00:23	KB
Client Sample Description		SOBWF1-1-102 Classroom 102	Collected:		12/18/2021 7:06:00 AM	Lab ID:		012115041-0005
Method	Parameter	Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS								
200.8	Lead	3.62	1.00 µg/L		1/4/2022	KB	1/5/2022 00:28	KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012115041

CustomerID: RAMA51

CustomerPO: 21-226

ProjectID:

Attn: **Fred Larson**
EnviroVision Consultants, Inc
20-21 Wagaraw Rd
Bldg 35E
Fair Lawn, NJ 07410

Phone: (973) 636-9145
Fax: (973) 636-9144
Received: 12/20/2021 09:00 AM

Project: 21-226 Scotch Plains/ Fanwood PS-School One ES

Analytical Results

Client Sample Description SODWF1-1-103
Classroom 103

Collected: 12/18/2021
7:13:00 AM

Lab ID: 012115041-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	2.45	1.00 µg/L	1/4/2022 KB	1/5/2022 14:04 JW
-------	------	------	-----------	-------------	-------------------

Client Sample Description SODWF1-1-112
Classroom 112

Collected: 12/18/2021
7:17:00 AM

Lab ID: 012115041-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	1.54	1.00 µg/L	1/4/2022 KB	1/5/2022 00:29 KB
-------	------	------	-----------	-------------	-------------------

Client Sample Description SODWF1-1-111
Classroom 111

Collected: 12/18/2021
7:20:00 AM

Lab ID: 012115041-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	1.52	1.00 µg/L	1/4/2022 KB	1/5/2022 00:31 KB
-------	------	------	-----------	-------------	-------------------

Client Sample Description SODWF1-1-104
Classroom 104

Collected: 12/18/2021
7:24:00 AM

Lab ID: 012115041-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	1.50	1.00 µg/L	1/4/2022 KB	1/5/2022 00:32 KB
-------	------	------	-----------	-------------	-------------------

Client Sample Description SODWF1-1-105
Classroom 105

Collected: 12/18/2021
7:27:00 AM

Lab ID: 012115041-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	1.83	1.00 µg/L	1/4/2022 KB	1/5/2022 00:33 KB
-------	------	------	-----------	-------------	-------------------

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012115041
CustomerID: RAMA51
CustomerPO: 21-226
ProjectID:

Attn: **Fred Larson**
EnviroVision Consultants, Inc
20-21 Wagaraw Rd
Bldg 35E
Fair Lawn, NJ 07410

Phone: (973) 636-9145
Fax: (973) 636-9144
Received: 12/20/2021 09:00 AM

Project: 21-226 Scotch Plains/ Fanwood PS-School One ES

Analytical Results

Client Sample Description		SODWF1-1-106 Classroom 106	Collected:		12/18/2021 7:29:00 AM	Lab ID:		012115041-0011
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst			
METALS								
200.8	Lead	5.81	1.00 µg/L	1/4/2022 KB	1/5/2022 00:35		KB	
Client Sample Description		SODWF1-1-108 Classroom 108	Collected:		12/18/2021 7:31:00 AM	Lab ID:		012115041-0012
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst			
METALS								
200.8	Lead	5.05	1.00 µg/L	1/4/2022 KB	1/5/2022 00:36		KB	
Client Sample Description		SODWF1-1-109 Classroom 109	Collected:		12/18/2021 7:33:00 AM	Lab ID:		012115041-0013
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst			
METALS								
200.8	Lead	2.86	1.00 µg/L	1/4/2022 KB	1/5/2022 00:41		KB	
Client Sample Description		SODWF1-1-110 Classroom 110	Collected:		12/18/2021 7:37:00 AM	Lab ID:		012115041-0014
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst			
METALS								
200.8	Lead	2.56	1.00 µg/L	1/4/2022 KB	1/5/2022 00:45		KB	
Client Sample Description		SOWCF1-1GYM1U Hallway at Gym 122	Collected:		12/18/2021 7:43:00 AM	Lab ID:		012115041-0015
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst			
METALS								
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 00:47		KB	

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012115041
CustomerID: RAMA51
CustomerPO: 21-226
ProjectID:

Attn: **Fred Larson**
EnviroVision Consultants, Inc
20-21 Wagaraw Rd
Bldg 35E
Fair Lawn, NJ 07410

Phone: (973) 636-9145
Fax: (973) 636-9144
Received: 12/20/2021 09:00 AM

Project: 21-226 Scotch Plains/ Fanwood PS-School One ES

Analytical Results

Client Sample Description		SOWCF1-1GYM1L Hallway at Gym 122		Collected:	12/18/2021 7:43:00 AM	Lab ID:	012115041-0016
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst	
METALS							
200.8	Lead	ND	1.00 µg/L	1/4/2022	KB	1/5/2022 00:48	KB
Client Sample Description		SODWF1-1-107 Classroom 107		Collected:	12/18/2021 7:45:00 AM	Lab ID:	012115041-0017
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst	
METALS							
200.8	Lead	3.28	1.00 µg/L	1/4/2022	KB	1/5/2022 00:50	KB
Client Sample Description		SODWF1-1-130 Classroom 130		Collected:	12/18/2021 7:48:00 AM	Lab ID:	012115041-0018
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst	
METALS							
200.8	Lead	1.65	1.00 µg/L	1/4/2022	KB	1/5/2022 00:51	KB
Client Sample Description		SODWF1-1-131 Classroom 131		Collected:	12/18/2021 7:54:00 AM	Lab ID:	012115041-0019
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst	
METALS							
200.8	Lead	2.47	1.00 µg/L	1/4/2022	KB	1/5/2022 00:53	KB
Client Sample Description		SOWCFL-2-200-1U Hallway at 200		Collected:	12/18/2021 8:03:00 AM	Lab ID:	012115041-0020
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst	
METALS							
200.8	Lead	ND	1.00 µg/L	1/4/2022	KB	1/5/2022 00:54	KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012115041
CustomerID: RAMA51
CustomerPO: 21-226
ProjectID:

Attn: **Fred Larson**
EnviroVision Consultants, Inc
20-21 Wagaraw Rd
Bldg 35E
Fair Lawn, NJ 07410

Phone: (973) 636-9145
Fax: (973) 636-9144
Received: 12/20/2021 09:00 AM

Project: 21-226 Scotch Plains/ Fanwood PS-School One ES

Analytical Results

Client Sample Description		SOWCFL-2-200-1L Hallway at 200	Collected:	12/18/2021 8:03:00 AM	Lab ID:	012115041-0021	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst		
METALS							
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 00:56	KB	
Client Sample Description		SOWCFL-2-200-1BF Hallway at 200	Collected:	12/18/2021 8:03:00 AM	Lab ID:	012115041-0022	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst		
METALS							
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 01:04	KB	
Client Sample Description		SODWF1-2-201 Classroom 201	Collected:	12/18/2021 8:07:00 AM	Lab ID:	012115041-0023	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst		
METALS							
200.8	Lead	1.94	1.00 µg/L	1/4/2022 KB	1/5/2022 01:09	KB	
Client Sample Description		SODWF1-2-202 Classroom 202	Collected:	12/18/2021 8:10:00 AM	Lab ID:	012115041-0024	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst		
METALS							
200.8	Lead	5.41	1.00 µg/L	1/4/2022 KB	1/5/2022 01:10	KB	
Client Sample Description		SODWF1-2-203 Classroom 203	Collected:	12/18/2021 8:12:00 AM	Lab ID:	012115041-0025	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst		
METALS							
200.8	Lead	5.42	1.00 µg/L	1/4/2022 KB	1/5/2022 01:12	KB	

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4671

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012115041
CustomerID: RAMA51
CustomerPO: 21-226
ProjectID:

Attn: **Fred Larson**
EnviroVision Consultants, Inc
20-21 Wagaraw Rd
Bldg 35E
Fair Lawn, NJ 07410

Phone: (973) 636-9145
Fax: (973) 636-9144
Received: 12/20/2021 09:00 AM

Project: 21-226 Scotch Plains/ Fanwood PS-School One ES

Analytical Results

Client Sample Description SODWF1-2-213
Classroom 213
Collected: 12/18/2021 8:15:00 AM
Lab ID: 012115041-0026

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.63	1.00 µg/L	1/4/2022 KB	1/5/2022 01:13 KB

Client Sample Description SODWF1-2-212
Classroom 212
Collected: 12/18/2021 8:15:00 AM
Lab ID: 012115041-0027

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.07	1.00 µg/L	1/4/2022 KB	1/5/2022 01:15 KB

Client Sample Description SODWF1-2-211
Classroom 211
Collected: 12/18/2021 8:20:00 AM
Lab ID: 012115041-0028

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.90	1.00 µg/L	1/4/2022 KB	1/5/2022 01:16 KB

Client Sample Description SODWF1-2-204
Classroom 204
Collected: 12/18/2021 8:23:00 AM
Lab ID: 012115041-0029

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.81	1.00 µg/L	1/4/2022 KB	1/5/2022 01:21 KB

Client Sample Description SODWF1-2-205
Classroom 205
Collected: 12/18/2021 8:25:00 AM
Lab ID: 012115041-0030

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.82	1.00 µg/L	1/4/2022 KB	1/5/2022 01:22 KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012115041

CustomerID: RAMA51

CustomerPO: 21-226

ProjectID:

Attn: **Fred Larson**
EnviroVision Consultants, Inc
20-21 Wagaraw Rd
Bldg 35E
Fair Lawn, NJ 07410

Phone: (973) 636-9145
Fax: (973) 636-9144
Received: 12/20/2021 09:00 AM

Project: 21-226 Scotch Plains/ Fanwood PS-School One ES

Analytical Results

Client Sample Description		SODWF1-2-206 Classroom 206	Collected:		12/18/2021 8:27:00 AM	Lab ID:		012115041-0031
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst			
METALS								
200.8	Lead	4.68	1.00 µg/L	1/4/2022 KB	1/5/2022 01:24	KB		
Client Sample Description		SODWF1-2-207 Classroom 207	Collected:		12/18/2021 8:30:00 AM	Lab ID:		012115041-0032
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst			
METALS								
200.8	Lead	2.08	1.00 µg/L	1/4/2022 KB	1/5/2022 01:25	KB		
Client Sample Description		SODWF1-2-208 Classroom 208	Collected:		12/18/2021 8:32:00 AM	Lab ID:		012115041-0033
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst			
METALS								
200.8	Lead	3.24	1.00 µg/L	1/4/2022 KB	1/5/2022 01:29	KB		
Client Sample Description		SODWF1-2-209 Classroom 209	Collected:		12/18/2021 8:34:00 AM	Lab ID:		012115041-0034
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst			
METALS								
200.8	Lead	12.5	1.00 µg/L	1/4/2022 KB	1/5/2022 01:31	KB		
Client Sample Description		SODWF1-2-210 Classroom 210	Collected:		12/18/2021 8:36:00 AM	Lab ID:		012115041-0035
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst			
METALS								
200.8	Lead	4.00	1.00 µg/L	1/4/2022 KB	1/5/2022 01:32	KB		

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012115041
CustomerID: RAMA51
CustomerPO: 21-226
ProjectID:

Attn: **Fred Larson**
EnviroVision Consultants, Inc
20-21 Wagaraw Rd
Bldg 35E
Fair Lawn, NJ 07410

Phone: (973) 636-9145
Fax: (973) 636-9144
Received: 12/20/2021 09:00 AM

Project: 21-226 Scotch Plains/ Fanwood PS-School One ES

Analytical Results

Client Sample Description SO-B
Blank
Collected: 12/18/2021
8:37:00 AM
Lab ID: 012115041-0036

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 01:34 KB

Definitions:

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results

EMSL ANALYTICAL, INC.
TESTING LABORATORY PRODUCTS TRAININGLead Chain of Custody
EMSL Order Number / Lab Use Only

012115041

EMSL Analytical, Inc.
200 Route 130 North
Cinnaminson, NJ 08077

PHONE: (800) 220-3675

EMAIL: Cinnaminson@emsl.com

Customer ID: RAMA51		Billing ID: RAMA51	
Company Name: EnviroVision Consultants, Inc.		Company Name: EnviroVision Consultants, Inc.	
Contact Name: Frederick Larson		Billing Contact: Frederick Larson	
Street Address: 20-21 Wagaraw Road, Bldg 35E		Street Address: 20-21 Wagaraw Road, Bldg 35E	
City, State, Zip: Fair Lawn, NJ 07410	Country: USA	City, State, Zip: Fair Lawn, NJ 07410	Country:
Phone: 973-636-9145		Phone: 973-636-9145	
Email(s) for Report: info@envirovisionconsultants.com		Email(s) for Invoice: info@envirovisionconsultants.com	

Project Name: 21-226 Scotch Plains/Fanwood PS - School One ES		Purchase Order: 21-226
EMSL LMS Project ID: 012115041		US State where samples collected: NJ
State of Connecticut (CT) must select project location:		
Commercial (Taxable) ☐ Residential (Non-Taxable) ☐		
Signed by: <i>Clay D. Nardo</i>		No. of Samples in Shipment
Turn-Around-Time (TAT)		
☐ 2 Hour ☐ 6 Hour ☐ 24 Hour ☐ 32 Hour ☐ 48 Hour ☐ 72 Hour ☐ 96 Hour ☐ 1 Week ☒ 2 Weeks		
Please call ahead for large projects and/or turnaround times 6 Hours or Less. *32 Hour TAT available for select tests only, samples must be submitted by 11:30am.		

MATRIX	METHOD	INSTRUMENT	REPORTING LIMIT	SELECTION
CHIPS ☐ by wt. ☐ by length ☐ by length	SW 846-7000B	Flame Atomic Absorption	0.008% (80ppm)	☐
Reporting Limit based on a minimum 0.25g sample weight	SW 846-60100	ICP-OES	0.0004% (4ppm)	☐
AIR	NIOSH 7082	Flame Atomic Absorption	4µg/m³	☐
	NIOSH 7300M / NIOSH 7303M	ICP-OES	0.1µg/m³	☐
	NIOSH 7300M / NIOSH 7303M	ICP-MS	0.05µg/m³	☐
WIPE ☐ ASTM ☐ NON-ASTM	SW 846-7000B	Flame Atomic Absorption	10µg/wipe	☐
If no box is checked, non-ASTM Wipe is assumed.	SW 846-60100	ICP-OES	1.0µg/wipe	☐
TCPLP	SW 846-1311 / 7000B / SM 3111B	Flame Atomic Absorption	0.4 mg/L (ppm)	☐
	SW 846-1311 / SW 846-60100*	ICP-OES	0.1 mg/L (ppm)	☐
SPLP	SW 846-1312 / 7000B / SM 3111B	Flame Atomic Absorption	0.4 mg/L (ppm)	☐
	SW 846-1312 / SW 846-60100*	ICP-OES	0.1 mg/L (ppm)	☐
TTLC	22 CCR App. II, 7000B	Flame Atomic Absorption	40mg/kg (ppm)	☐
	22 CCR App. II, SW 846-60100*	ICP-OES	2mg/kg (ppm)	☐
STLC	22 CCR App. II, 7000B	Flame Atomic Absorption	0.4 mg/L (ppm)	☐
	22 CCR App. II, SW 846-60100*	ICP-OES	0.1 mg/L (ppm)	☐
Soil	SW 846-7000B	Flame Atomic Absorption	40mg/kg (ppm)	☐
	SW 846-60100*	ICP-OES	2mg/kg (ppm)	☐
SM 3111B / SW 846-7000B	Flame Atomic Absorption	0.4 mg/L (ppm)	☐	
Wastewater	EPA 200.7	ICP-OES	0.020 mg/L (ppm)	☐
Unpreserved	EPA 200.5	ICP-OES	0.003 mg/L (ppm)	☐
Preserved with HNO3 ☐ PH<2	EPA 200.6	ICP-MS	0.001 mg/L (ppm)	☐
Drinking Water				☐
Unpreserved				☐
Preserved with HNO3 ☐ PH<2				☐
TSP/SPM Filter	40 CFR Part 50	ICP-OES	12 µg/filter	☐
Other:				☐

Sample Number	Sample Location	Volume / Area	Date / Time Sampled
1 SOWCFI-1-128V	Hall By 128	250 mL	12/18/21 7:00AM
2 SOWCFI-1-128L	Hall By 128	250 mL	12/18/21 7:00AM
3 SOWCFI-1-128BF	Hall By 128	250 mL	12/18/21 7:00 PM
4 SOWCFI-1-101	Classroom 101	250 mL	12/18/21 7:04 AM
5 SOWCFI-1-102	Classroom 102	250 mL	12/18/21 7:06 AM

Method of Shipment: <i>Drop Off</i>		Sample Condition Upon Receipt:	
Relinquished by: <i>Clay D. Nardo</i>	Date/Time: <i>12/18/21</i>	Received by: <i>W F</i>	Date/Time: <i>12/18/21 1:25 PM</i>
Relinquished by:	Date/Time:	Received by: <i>Thomas H. W1</i>	Date/Time: <i>12/20/21 9:00 AM</i>

Controlled Document - CDP-28 Lab R16 4/19/2021

*9010C Available Upon Request

☐ AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.

Page 1 of 2

15.2^c



EMSL ANALYTICAL, INC.
TESTING LABS • PRODUCTS • TRAINING

Lead Chain of Custody

EMSL Order Number / Lab Use Only

EMSL Analytical, Inc.
200 Route 130 North
Cinnaminson, NJ 08077

PHONE: (800) 220-3875

EMAIL: CinnaminsonLeadLab@emsl.com

012115041

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information.

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)

School ONE ES

Sample Number	Sample Location	Volume / Area	Date / Time Sampled
6 SODWFI-1-103	Classroom 103	250 ML	12/18/21 713
7 SODWFI-1-112	Classroom 112	250 ML	12/18/21 717
8 SODWFI-1-111	Classroom 111	250 ML	12/18/21 720
9 SODWFI-1-104	Classroom 104	250 ML	12/18/21 724
10 SODWFI-1-105	Classroom 105	250 ML	12/18/21 727
11 SODWFI-1-106	Classroom 106	250 ML	12/18/21 729
12 SODWFI-1-108	Classroom 108	250 ML	12/18/21 731
13 SODWFI-1-109	Classroom 109	250 ML	12/18/21 733
14 SODWFI-1-110	Classroom 110	250 ML	12/18/21 737
15 SOWCFI-1-gym-1U	Hallway at gym 122	250 ML	12/18/21 743
16 SOWCFI-1-gym-1L	Hallway at gym 122	250 ML	12/18/21 743
17 SODWFI-1-107	Classroom 107	250 ML	12/18/21 745
18 SODWFI-1-130	Classroom 130	250 ML	12/18/21 748
19 SODWFI-1-131	Classroom 131	250 ML	12/18/21 754
20 SOWCFI-2-200-1U	Hallway at 200	250 ML	12/18/21 803
21 SOWCFI-2-200-1L	Hallway at 200	250 ML	12/18/21 803
22 SOWCFI-2-200-1BF	Hallway at 200	250 ML	12/18/21 803
23 SODWFI-2-201	Classroom 201	250 ML	12/18/21 807
24 SODWFI-2-202	Classroom 202	250 ML	12/18/21 810
25 SODWFI-2-203	Classroom 203	250 ML	12/18/21 812
26 SODWFI-2-213	Classroom 213	250 ML	12/18/21 815
27 SODWFI-2-212	Classroom 212	250 ML	12/18/21 820
28 SODWFI-2-211	Classroom 211	250 ML	12/18/21 820
29 SODWFI-2-204	Classroom 204	250 ML	12/18/21 823
30 SODWFI-2-205	Classroom 205	250 ML	12/18/21 825

Method of Shipment:

Drop off

Sample Condition Upon Receipt:

Received by:

C. Dina

Date/Time:

12/19/21

Received by:

Date/Time:

Relinquished by:

Date/Time:

Received by:

Date/Time:

Controlled Document - CDC-29 Lead R16 4/19/2021



AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.

EMSL Order Number / Lab Use Only

EMAIL: CinnamineonLeadLab@gmail.com

EMSL ANALYTICAL, INC.
TESTING LABS • PRODUCTS • TRAINING

Additional Pages at the Office of Consular are only necessary if requested for additional information.

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)

School ONE ES

Method of Experiment

Sample Condition Upon Receipt:

Received by:

Estimated Time _____

Reinforced by:

Date/Time:

Received by:

Order Times

Controlled Document - COC-26 Lead R18 4/19/2025

AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.