



20-21 Wagaraw Road – Bldg. 35E, Fair Lawn, NJ 07410
PH (973) 636-9145 FAX (973) 636-9144
Email: Envirovision@optonline.net

CLIENT: Scotch Plains – Fanwood School District Project No. 21-226
PROJECT: Lead (Pb) in Water Sampling Terrill Middle School
ADDRESS: 1301 Terrill Rd, Scotch Plains, NJ 07076
FIELD TECHNICIAN(S) Jordan Pryske
REPORT DATE: January 11, 2022

As per your request, EnviroVision Consultants, Inc. was contracted by Scotch Plains – Fanwood School District to conduct Lead (Pb) in water sampling at the Terrill Middle School on December 18, 2021. The sample locations, in addition to a unique sample location code was determined/assigned by school district personnel. The school district performed the proper flushing of outlets prior to sampling and EnviroVision was instructed to collect only first draw samples for this sampling event. The school district's corresponding flushing logs should be attached to this report.

The facility was closed at the time of sampling in order to prevent occupants from utilizing any water outlets. After flushing, the water in the facility must remain motionless in the plumbing fixtures for a minimum of 8 hours, but no more than 48 hours. Cold water samples were collected in pre-cleaned high-density polyethylene (HDPE) 250mL wide mouth bottles.

Samples were analyzed at EMSL Analytical Inc. in Cinnaminson, New Jersey *(NJDEP# 03036), accredited in accordance with NELAC (National Environmental Laboratory Accreditation Conference). The analytical method utilized was inductively coupled plasma mass spectrometry ICP-MS (EPA 200.8).

All thirty initially requested samples were collected from Terrill Middle School. A blank sample was also collected as required.

Results: All of the samples analyzed were either "None Detected" or less than the EPA established threshold for lead in drinking water of 15 parts per billion (ppb). The action level has been further defined for compliance by the New Jersey Department of Environmental Protection Agency as an amount greater than or equal to 15.5 ug/L (1ug/L = 1ppb). When a water outlet/faucet meets or exceeds the USEPA/NJDEP threshold, EnviroVision recommends that the outlet/faucet be immediately put out of service until the system can be further evaluated and proper remedial action is achieved.



Page 2 (Terrill MS)

Project Number 21-226

If you have any questions, or if we could be of any further assistance, please feel free to contact our office. EnviroVision looks forward to providing you with the service and attention to detail you have come to expect from us.

Sincerely,
EnviroVision Consultants, Inc.

Cathy DiNardo

Cathy DiNardo, Project Manager

Attached: Lab results, Associated data sheets,



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn: **Frederick Larson**
EnviroVision Consultants, Inc
20-21 Wagaraw Rd
Bldg 35E
Fair Lawn, NJ 07410

1/6/2022

Phone: (973) 636-9145

Fax: (973) 636-9144

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 12/20/2021. The results are tabulated on the attached data pages for the following client designated project:

21-226 Scotch Plains/Fanwood PS - Terrill MS

The reference number for these samples is EMSL Order #012115038. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012115038
CustomerID: RAMA51
CustomerPO: 21-226
ProjectID:

Attn: **Frederick Larson**
EnviroVision Consultants, Inc
20-21 Wagaraw Rd
Bldg 35E
Fair Lawn, NJ 07410

Phone: (973) 636-9145
Fax: (973) 636-9144
Received: 12/20/2021 09:00 AM

Project: 21-226 Scotch Plains/Fanwood PS - Terrill MS

Analytical Results

Client Sample Description		TL.WC.FI-1.MainOff Hallway Main Office	Collected:	12/18/2021 10:02:00 AM	Lab ID:	012115038-0001	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst		
METALS							
200.8	Lead	2.91	1.00 µg/L	1/4/2022 KB	1/5/2022 13:39 JW		
Client Sample Description		TL.WC.FI-1.Counseling Hallway - Counseling	Collected:	12/18/2021 10:03:00 AM	Lab ID:	012115038-0002	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst		
METALS							
200.8	Lead	6.70	1.00 µg/L	1/4/2022 KB	1/5/2022 01:46 KB		
Client Sample Description		TL.WC.FI-1.1-2U Hallway Near Room 1	Collected:	12/18/2021 10:05:00 AM	Lab ID:	012115038-0003	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst		
METALS							
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 01:50 KB		
Client Sample Description		TL.WC.FI-1.1-2L Hallway Near Room 1	Collected:	12/18/2021 10:07:00 AM	Lab ID:	012115038-0004	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst		
METALS							
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 01:52 KB		
Client Sample Description		TL.WC.FI-1.1-2BF Hallway Near Room 1	Collected:	12/18/2021 10:08:00 AM	Lab ID:	012115038-0005	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst		
METALS							
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 01:59 KB		

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012115038

CustomerID: RAMA51

CustomerPO: 21-226

ProjectID:

Attn: **Frederick Larson**
EnviroVision Consultants, Inc
20-21 Wagaraw Rd
Bldg 35E
Fair Lawn, NJ 07410

Phone: (973) 636-9145
Fax: (973) 636-9144
Received: 12/20/2021 09:00 AM

Project: 21-226 Scotch Plains/Fanwood PS - Terrill MS

Analytical Results

Client Sample Description		TL.WC.FI-1.Auditorium-1 Auditorium Hall	Collected:		12/18/2021 10:10:00 AM	Lab ID:		012115038-0006	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead		ND	1.00 µg/L		1/4/2022	KB	1/5/2022 02:00	KB
Client Sample Description		TL.WC.FI-1.Auditorium-2 Auditorium Hall	Collected:		12/18/2021 10:11:00 AM	Lab ID:		012115038-0007	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead		ND	1.00 µg/L		1/4/2022	KB	1/5/2022 02:02	KB
Client Sample Description		TL.WC.FI-1.11A-1U Hall at 11A	Collected:		12/18/2021 10:13:00 AM	Lab ID:		012115038-0008	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead		ND	1.00 µg/L		1/4/2022	KB	1/5/2022 02:03	KB
Client Sample Description		TL.WC.FI-1.11A-1L Hall at 11A	Collected:		12/18/2021 10:14:00 AM	Lab ID:		012115038-0009	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead		ND	1.00 µg/L		1/4/2022	KB	1/5/2022 02:05	KB
Client Sample Description		TL.WC.FI-1.11A-1BF Hall at 11A	Collected:		12/18/2021 10:15:00 AM	Lab ID:		012115038-0010	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead		ND	1.00 µg/L		1/4/2022	KB	1/5/2022 02:06	KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012115038
CustomerID: RAMA51
CustomerPO: 21-226
ProjectID:

Attn: **Frederick Larson**
EnviroVision Consultants, Inc
20-21 Wagaraw Rd
Bldg 35E
Fair Lawn, NJ 07410

Phone: (973) 636-9145
Fax: (973) 636-9144
Received: 12/20/2021 09:00 AM

Project: 21-226 Scotch Plains/Fanwood PS - Terrill MS

Analytical Results

Client Sample Description		TL.WC.FI-1.Music Music Room	Collected:		12/18/2021 10:17:00 AM	Lab ID:		012115038-0011	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead		1.63	1.00 µg/L		1/4/2022	KB	1/5/2022 02:08	KB
Client Sample Description		TL.WC.FI-1.MPR-1 MPR Room	Collected:		12/18/2021 10:19:00 AM	Lab ID:		012115038-0012	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead		ND	1.00 µg/L		1/4/2022	KB	1/5/2022 02:09	KB
Client Sample Description		TL.WC.FI-1.MPR-2 MPR Room	Collected:		12/18/2021 10:20:00 AM	Lab ID:		012115038-0013	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead		ND	1.00 µg/L		1/4/2022	KB	1/5/2022 02:17	KB
Client Sample Description		TL.WC.FI-1.19-1U Hallway 19	Collected:		12/18/2021 10:23:00 AM	Lab ID:		012115038-0014	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead		2.63	1.00 µg/L		1/4/2022	KB	1/5/2022 02:18	KB
Client Sample Description		TL.WC.FI-1.19-1L Hallway 19	Collected:		12/18/2021 10:24:00 AM	Lab ID:		012115038-0015	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead		2.71	1.00 µg/L		1/4/2022	KB	1/5/2022 02:20	KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012115038

CustomerID: RAMA51

CustomerPO: 21-226

ProjectID:

Attn: **Frederick Larson**
EnviroVision Consultants, Inc
20-21 Wagaraw Rd
Bldg 35E
Fair Lawn, NJ 07410

Phone: (973) 636-9145
 Fax: (973) 636-9144
 Received: 12/20/2021 09:00 AM

Project: 21-226 Scotch Plains/Fanwood PS - Terrill MS

Analytical Results

Client Sample Description TL.DW.FI-1.18
Room 18
Collected: 12/18/2021
10:26:00 AM
Lab ID: 012115038-0016

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.16	1.00 µg/L	1/4/2022 KB	1/5/2022 02:21 KB

Client Sample Description TL.WC.Villa.1/2-1
Villa Hallway Between 1 and 2
Collected: 12/18/2021
10:30:00 AM
Lab ID: 012115038-0017

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.24	1.00 µg/L	1/4/2022 KB	1/5/2022 02:23 KB

Client Sample Description TL.WC.Villa.3/4-2
Villa Hallway Between 3 and 4
Collected: 12/18/2021
10:33:00 AM
Lab ID: 012115038-0018

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 02:24 KB

Client Sample Description TL.WC.FI-1.Cafe-1F
Outside Cafeteria
Collected: 12/18/2021
10:38:00 AM
Lab ID: 012115038-0019

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 02:25 KB

Client Sample Description TL.WC.FI-1.Cafe-1BF
Outside Cafeteria
Collected: 12/18/2021
10:39:00 AM
Lab ID: 012115038-0020

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 02:27 KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012115038
CustomerID: RAMA51
CustomerPO: 21-226
ProjectID:

Attn: **Frederick Larson**
EnviroVision Consultants, Inc
20-21 Wagaraw Rd
Bldg 35E
Fair Lawn, NJ 07410

Phone: (973) 636-9145
Fax: (973) 636-9144
Received: 12/20/2021 09:00 AM

Project: 21-226 Scotch Plains/Fanwood PS - Terrill MS

Analytical Results

Client Sample Description TL.WC.FI-1.Cafe-2
Outside Cafeteria
Collected: 12/18/2021
10:40:00 AM
Lab ID: 012115038-0021

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 02:31 KB
-------	------	----	-----------	-------------	-------------------

Client Sample Description TL.WC.FI-1.Cafe-3
Inside Cafeteria
Collected: 12/18/2021
10:42:00 AM
Lab ID: 012115038-0022

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	15.1	1.00 µg/L	1/4/2022 KB	1/5/2022 03:19 KB
-------	------	------	-----------	-------------	-------------------

Client Sample Description TL.WC.FI-1.Cafe-4
Inside Cafeteria
Collected: 12/18/2021
10:43:00 AM
Lab ID: 012115038-0023

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	12.5	1.00 µg/L	1/4/2022 KB	1/5/2022 03:26 KB
-------	------	------	-----------	-------------	-------------------

Client Sample Description TL.WC.FI-1.Locker B
Boys Locker Room
Collected: 12/18/2021
10:46:00 AM
Lab ID: 012115038-0024

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	2.44	1.00 µg/L	1/4/2022 KB	1/5/2022 03:27 KB
-------	------	------	-----------	-------------	-------------------

Client Sample Description TL.WC.FI-1.Locker G
Girls Locker Room
Collected: 12/18/2021
10:48:00 AM
Lab ID: 012115038-0025

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	1.07	1.00 µg/L	1/4/2022 KB	1/5/2022 03:29 KB
-------	------	------	-----------	-------------	-------------------

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012115038

CustomerID: RAMA51

CustomerPO: 21-226

ProjectID:

Attn: **Frederick Larson**
EnviroVision Consultants, Inc
20-21 Wagaraw Rd
Bldg 35E
Fair Lawn, NJ 07410

Phone: (973) 636-9145
Fax: (973) 636-9144
Received: 12/20/2021 09:00 AM

Project: 21-226 Scotch Plains/Fanwood PS - Terrill MS

Analytical Results

Client Sample Description		TL.WC.FI-2.28-1 Hallway 28	Collected:		12/18/2021 10:52:00 AM	Lab ID:		012115038-0026	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead		ND	1.00 µg/L		1/4/2022 KB		1/5/2022 03:30 KB	
Client Sample Description		TL.WC.FI-2.28-2 Hallway 28	Collected:		12/18/2021 10:53:00 AM	Lab ID:		012115038-0027	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead		ND	1.00 µg/L		1/4/2022 KB		1/5/2022 03:32 KB	
Client Sample Description		TL.WC.FI-2.35-1 Hallway 35	Collected:		12/18/2021 10:55:00 AM	Lab ID:		012115038-0028	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead		1.48	1.00 µg/L		1/4/2022 KB		1/5/2022 03:33 KB	
Client Sample Description		TL.WC.FI-2.35-2 Hallway 35	Collected:		12/18/2021 10:56:00 AM	Lab ID:		012115038-0029	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead		3.19	1.00 µg/L		1/4/2022 KB		1/5/2022 15:11 KB	
Client Sample Description		TL.DW.FI-2.36 Classroom 36	Collected:		12/18/2021 10:58:00 AM	Lab ID:		012115038-0030	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead		2.47	1.00 µg/L		1/4/2022 KB		1/5/2022 03:36 KB	

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012115038

CustomerID: RAMA51

CustomerPO: 21-226

ProjectID:

Attn: **Frederick Larson**
EnviroVision Consultants, Inc
20-21 Wagaraw Rd
Bldg 35E
Fair Lawn, NJ 07410

Phone: (973) 636-9145
Fax: (973) 636-9144
Received: 12/20/2021 09:00 AM

Project: **21-226 Scotch Plains/Fanwood PS - Terrill MS****Analytical Results**

Client Sample Description TL-Blank

Collected: 12/18/2021
11:00:00 AM

Lab ID: 012115038-0031

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 03:38 KB

Definitions:

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results

EMSL

Lead Chain of Custody

EMSL Order Number / Lab Use Only

EMSL Analytical, Inc.

200 Route 130 North

Cinnaminson, NJ 08077

EMSL ANALYTICAL, INC.
TESTING LABS • PRODUCTS • TRAINING

012115038

PHONE: (800) 220-3675

EMAIL: CinnaminsonLeadLab@emsl.com

Customer ID: RAMA51		Billing ID: RAMA51	
Company Name: EnviroVision Consultants, Inc.		Company Name: EnviroVision Consultants, Inc.	
Contact Name: Frederick Larson		Billing Contact: Frederick Larson	
Street Address: 20-21 Wagaraw Road, Bldg 35E		Street Address: 20-21 Wagaraw Road, Bldg 35E	
City, State, Zip: Fair Lawn, NJ 07410		City, State, Zip: Fair Lawn, NJ 07410	
Country: USA		Country:	
Phone: 973-636-9145		Phone: 973-636-9145	
Email(s) for Report: info@envirovisionconsultants.com		Email(s) for Invoice: info@envirovisionconsultants.com	

Project Name/No: 21-226 Scotch Plains/Fanwood PS - Terrill MS		Purchase Order: 21-226	
EMSL LIMS Project ID: (If applicable, EMSL will provide)		US State where samples collected: NJ	
Sampled By Name: Jordan Pysko		State of Connecticut (CT) must select project location: ☐ Commercial (Taxable) ☐ Residential (Non-Taxable)	
Sampled By Signature: [Signature]		No. of Samples in Shipment	

Turn-Around-Time (TAT)

☐ 3 Hour ☐ 6 Hour ☐ 24 Hour ☐ 32 Hour ☐ 48 Hour ☐ 72 Hour ☐ 96 Hour ☐ 1 Week ☒ 2 Week

Please call ahead for large projects and/or turnaround times 5 hours or less. *32 Hour TAT available for select tests only, samples must be submitted by 11:30am.

MATRIX	METHOD	INSTRUMENT	REPORTING LIMIT	SELECTION
CHIPS ☐ % by wt. ☐ ppm (mg/kg) ☐ mg/cm ²	SW 846-7000B	Flame Atomic Absorption	0.008% (80ppm)	☐
Reporting Limit based on a minimum 0.25g sample weight	SW 846-6010D	ICP-OES	0.0004% (4ppm)	☐
	NIOSH 7082	Flame Atomic Absorption	4µg/filter	☐
AIR	NIOSH 7300M / NIOSH 7303M	ICP-OES	0.5µg/filter	☐
	NIOSH 7300M / NIOSH 7303M	ICP-MS	0.05µg/filter	☐
WIPE ☐ ASTM ☐ NON-ASTM	SW 846-7000B	Flame Atomic Absorption	10µg/wipe	☐
If no box is checked, non-ASTM Wipe is assumed	SW 846-6010D	ICP-OES	1.0µg/wipe	☐
TCLP	SW 846-1311 / 7000B / SM 3111B	Flame Atomic Absorption	0.4 mg/L (ppm)	☐
	SW 846-1311 / SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	☐
SPLP	SW 846-1312 / 7000B / SM 3111B	Flame Atomic Absorption	0.4 mg/L (ppm)	☐
	SW 846-1312 / SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	☐
TTLC	22 CCR App. II, 7000B	Flame Atomic Absorption	40mg/kg (ppm)	☐
	22 CCR App. II, SW 846-6010D*	ICP-OES	2mg/kg (ppm)	☐
STLC	22 CCR App. II, 7000B	Flame Atomic Absorption	0.4 mg/L (ppm)	☐
	22 CCR App. II, SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	☐
Soil	SW 846-7000B	Flame Atomic Absorption	40mg/kg (ppm)	☐
	SW 846-6010D*	ICP-OES	2mg/kg (ppm)	☐
Wastewater	SM 3111B / SW 846-7000B	Flame Atomic Absorption	0.4 mg/L (ppm)	☐
Unpreserved				☐
Preserved with HNO3	EPA 200.7	ICP-OES	0.020 mg/L (ppm)	☐
Drinking Water	EPA 200.5	ICP-OES	0.003 mg/L (ppm)	☐
Unpreserved				☐
Preserved with HNO3	EPA 200.8	ICP-MS	0.001 mg/L (ppm)	☐
TSP/SPM Filter	40 CFR Part 50	ICP-OES	12 µg/filter	☐
Other:				☐

Sample Number	Sample Location	Volume / Area	Date / Time Sampled
1 TLWC.FI-1. Main Off	Hallway Main Office		12/18/01 1002
2 TLWC.FI-1. Counseling	Hallway - Counseling		1003
3 TLWC.FI-1.1-04	Hallway near Room 1		1005
4 TLWC.FI-1.1-02	Hallway near Room 1		1007
5 TLWC.FI-1.1-08	Hallway near Room 1		1008

Method of Shipment: Drop off		Sample Condition Upon Receipt:	
Requisitioned by: [Signature]	Date/Time: 12/18/01 1125	Received by: [Signature]	Date/Time: 12/18/01 1125
Relinquished by: [Signature]	Date/Time: 12/19/01	Received by: [Signature]	Date/Time: 12/19/01 8:25 AM

Controlled Document - CQC-25 Lead R16 4/19/2021

*5010C Available Upon Request

☐ AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.



EMSL ANALYTICAL, INC.
TESTING LABS • PRODUCTS • TRAINING

Lead Chain of Custody

EMSL Order Number / Lab Use Only

012115038

EMSL Analytical, Inc.
200 Route 130 North
Cinnaminson, NJ 08077

PHONE: (800) 220-3876

EMAIL: Cinnaminson@emsl.com

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)

Terrell MS

Sample Number	Sample Location	Volume / Area	Date / Time Sampled
6 TLWC.FI-1.Auditorium-1	Auditorium Hall		12/18/21 1010
7 TLWC.FI-1.Auditorium-2	Auditorium Hall		1011
8 TLWC.FI-1.11A-1U	Hall at 11A		1013
9 TLWC.FI-1.11A-1L	Hall at 11A		1014
10 TLWC.FI-1.11A-1BF	Hall at 11A		1015
11 TLWC.FI-1.Music	Music Room		1017
12 TLWC.FI-1.MPR-1	MPR Room		1019
13 TLWC.FI-1.MPR-2	MPR Room		1020
14 TLWC.FI-1.19-1U	Hallway 19		1023
15 TLWC.FI-1.19-1L	Hallway 19		1024
16 TLWC.FI-1.18	Room 18		1026
17 TLWC.Villa.1/2-1	Villa Hallway Between 1 and 2		1030
18 TLWC.Villa.3/4-2	Villa Hallway Between 3 and 4		1033
19 TLWC.FI-1.Cafe-1F	Outside Cafeteria		1038
20 TLWC.FI-1.Cafe-1BF	Outside Cafeteria		1039
21 TLWC.FI-1.Cafe-2	Outside Cafeteria		1040
22 TLWC.FI-1.Cafe-3	Inside Cafeteria		1042
23 TLWC.FI-1.Cafe-4	Inside Cafeteria		1043
24 TLWC.FI-1.LockerB	Boys Locker Room		1046
25 TLWC.FI-1.LockerC	Girls Locker Room		1048
26 TLWC.FI-2.28-1	Hallway 28		1050
27 TLWC.FI-2.28-2	Hallway 28		1053
28 TLWC.FI-2.35-1	Hallway 35		1055
29 TLWC.FI-2.35-2	Hallway 35		1056
30 TLWC.FI-2.36	Class Room 36		1058

Method of Shipment:

Sample Condition Upon Receipt:

Relinquished by:

M. W. W. W.

Date/Time:

12/18/21 11:25

Received by:

C. D. W. W.

Date/Time

12/18/21 11:25

Relinquished by:

C. D. W. W.

Date/Time:

12/18/21

Received by:

Date/Time

Controlled Document - CQC-25 (Lead R16 4/19/2021)



AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.

EMSL Order Number / Lab Use Only

EMAIL: Cinnamon@LeadLabz.com

EMSL ANALYTICAL, INC.
TESTING LABS • PRODUCTS • TRAINING

01215038

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information.

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)

Terrill MS

3) Blank

Order Type

AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

ENEL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to ENEL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.